



BUILDING CONSTRUCTION TEST LABORATORY

6 Gatewood Close, Padstow NSW 2211

Phone: 02 9772 2511 Fax: 02 9772 2557 Email: bctestlab@gmail.com

TEST CERTIFICATE

FOR REPORT NO. BCTL-18063

Manufacturer:

Qingdao Scaffolding Import and Export Co., Ltd
Room 2206-2210, Century Mansion,
39 Donghaixi Road, Qingdao, China

Distributor:

Round Scaffolding Pty Ltd
7 East Derrimut Crescent, Derrimut
Melbourne VIC Australia 3030

Test Product:

Green Formwork Early Stripping System Drop Head

Test Method Reference:

AS 3610: 1995 Appendix A

Test Comments:

The samples of Green Formwork Early Stripping System Drop Head tested and described in report BCTL-18063 satisfy the strength requirements in Appendix A, AS3610: 1995 for 500mm thick concrete slab pressure.

Notes:

1. Building Construction Test Laboratory Pty Ltd (BCTL) shall not be liable for loss, cost, damages or expenses incurred by the client or any other person or company, resulting from the use of any information or interpretation given in this report. In no case shall BCTL be liable for consequential damages including, but not limited to, lost profit, damages for failure to meet deadlines and lost production arising from this report. This document shall not be reproduced except in full and relates only to the items tested.
2. This report only indicated the compliance of the formwork head in its state at the time of testing. It should not be taken as a statement that all similar formwork heads in all states of repair, would also be found to comply.
3. It remains the responsibility of the client to ensure that the formwork heads as reported herein are representative of the entire production batch.
4. BCTL shall take no responsibility for the procurement and authenticity of the formwork heads as described herein.
5. BCTL shall take no responsibility for the installation procedures used for the formwork heads described herein.


Lida Song

B.E., M.E. PhD (Civil Eng), C.P. Eng.
NPER (659737), RPEQ (14348)
Date: 22/08/2018


Lang Lin
B.E. (Civil)



THE INTERNATIONAL CERTIFICATION NETWORK

CERTIFICATE

IQNet and CQM
hereby certify that the organization
Shandong Prima Formwork Co., Ltd.

Organization Code: 58182499-8
Domicile: North Economic Development Zone, Rizhao City, Shandong, P.R.China
Certification Add.: Rizhao Shihai Economic Development Zone, Rizhao City, Shandong, P.R.China

Post code: 262306
is in conformity with
ISO 9001:2008 Standard

This certificate is valid to the following product(s)/service:
Design, development and production of table style early stripping formwork system

Issued on: 2015-08-28
Effective date: 2015-08-28
Validity date: 2018-08-27
Registration Number: CN-00215Q15046R05



Michael Drechsel
President of IQNet

Ji XianDong
General Manager of CQM



*IQNet Partners**

A2302E Spain APNOR Certification France A2B Viasat International Belgium APCER Portugal CCC Cyprus
C39Q PolyCQC China CQM China CQB Czech Republic CQC Crestis CQB Holding GmbH Germany
FCAY Brazil FURDOORIMA Venezuela SCOTTEC Colombia ENSC Mexico Jaeger Certification Finland INTECO Costa Rica
IBAM Argentina JQA Japan KQF Korea MERTEC Greece MIST Hungary Sertek AS Norway SRS Ireland PCBC Poland
Quality Austria Austria KQF Russia SICE Mexico SE Israel SIQ Slovenia SIRM QAS International Malaysia
SQS Switzerland SRNC Romania TEST St Petersburg Russia TSE Turkey YUQB Serbia
IQNet is represented in the USA by: APNOR Certification, C39Q, CQC Holding GmbH and SRA Inc.
* The list of IQNet partners is valid at the time of issue of this certificate. Updated information is available under www.iqnet-certification.com

TEST CERTIFICATE

FOR REPORT MT-14/907

DISTRIBUTOR

ROUND SCAFFOLDING PTY LTD

26 VIKING COURT CHILTERNHAM

MELBOURNE VIC AUSTRALIA 3192

MANUFACTURER

QINGDAO SCAFFOLDING IMPORT AND EXPORT CO. LTD

ROOM 2206-2210 CENTURY MANSION

39 DONGHAIZI ROAD QINGDAO CHINA

EQUIPMENT DESIGNATION:

ADJUSTABLE TELESCOPIC 'GREEN FORMWORK' PROPS

TEST METHOD REFERENCE:

AS 3610-1995: FORMWORK FOR CONCRETE

AS 3610-1996: SUPPLEMENT NO. 2 COMMENTARY

As described and reported in Test Report No. MT-14/907, the adjustable telescopic 'Green Formwork' props have been tested at the Melbourne Testing Services (MTS) Laboratory in accordance with the general provisions for destructive testing as outlined by Appendix A of AS 3610-1995.

Testing confirms that the props can support a Working Load Limit (WLL) for each extension as follows:


Prop Extension (m)	Working Load Limit (WLL)	
	(kN)	(tonnes)
2.20	38	3.9
2.85	30	3.0
3.50	15	1.5

Notes:

- Melbourne Testing Services (MTS) Pty Ltd shall not be liable for loss, cost, damages or expenses incurred by the client or any other person or company, resulting from the use of any information or interpretation given in test report no. MT-14/907. In no case shall Melbourne Testing Services Pty Ltd be liable for consequential damages including, but not limited to, lost profits, damages for failure to meet deadlines and lost production arising from test report no. MT-14/907. This document shall not be reproduced except in full and solely only to the test item.
- The test report no. MT-14/907 only indicates compliance of the formwork props in their state at the time of testing. It should not be taken as a statement that all similar formwork props or components of formwork props in all states of repair, would also be found to comply.
- It remains the responsibility of the client to ensure that the formwork props as reported in test report no. MT-14/907 are representative of the entire production batch.
- The test report no. MT-14/907 covers the structural integrity of the formwork props specific to the requirements of AS 3610-1995 Appendix A3 & A4.
- MTS shall take no responsibility for the procurement and authenticity of the formwork props as described in test report no. MT-14/907.
- MTS shall take no responsibility for the installation procedures used for the formwork props described in test report no. MT-14/907.
- MTS shall take no responsibility for the performance of the tested props whereby the shear pin is not correctly positioned to ensure full bearing contact.
- MTS shall take no responsibility for the performance of the tested props whereby the shear pin is not suitably positioned to ensure full bearing contact.



ROB WILKIE
TEST ENGINEER
LABORATORY MANAGER
DATE: 11/12/2014



DAN HENBURY
TEST ENGINEER
BENG (MICH) HON

United States of America

United States Patent and Trademark Office



格林

GREEN FORMWORK

Reg. No. 4,378,508

Registered Aug. 6, 2013

Int. CL: 6

TRADEMARK

PRINCIPAL REGISTER

SHANDONG PRIMA FORMWORK CO., LTD. (CHINA LIMITED LIABILITY COMPANY)
RIZHAO NORTH NEW DEVELOPMENT PARK,
SHANDONG, CHINA

FOR BUILDING MATERIALS FOR ENVIRONMENTAL PURPOSES, NAMELY, COMPOSITE PANELS COMPOSED PRIMARILY OF METAL; FASTENERS, NAMELY, METAL BARS AND CHAINS; MATERIALS OF METAL FORM AFFOLDS; METAL FORMWORK TABLES; REINFORCING MATERIALS OF METAL FOR BUILDING AND ENVIRONMENTAL PURPOSES; STEEL IN SHEET, ROD, BAR AND/OR BILLET FORM; STEEL IN THE FORM OF SHEETS, PLATES, FOILS AND COILS; STEELS IN THE FORM OF SHEETS, PLATES, FOILS AND REELS, IN CLASS 6 (U.S. CLS. 2, 12, 13, 14, 23, 25 AND 56).

FIRST USE 5-1-2011; IN COMMERCE 2-10-2012.

NO CLAIM IS MADE TO THE EXCLUSIVE RIGHT TO USE "GREEN FORMWORK", APART FROM THE MARK AS SHOWN.

THE NON-LATIN CHARACTERS IN THE MARK TRANSLITERATE TO "GE LIN" AND THIS HAS NO MEANING IN A FOREIGN LANGUAGE.

THE MARK CONSISTS OF THE STYLIZED LETTERING "GF", "GREEN FORMWORK" AND TWO CHINESE CHARACTERS TRANSLITERATED INTO "GE LIN".

SER. NO. 85-407,365, FILED 4-25-2012.

REGINA DRUMMOND, EXAMINING ATTORNEY



Lisa H. Smith
Acting Director of the United States Patent and Trademark Office